

### **RICE Periodic Monitoring Procedure (PMP) Frequency Reduction Guidance**

A facility that has achieved and maintained compliance with the PMP may submit a modification request to reduce the frequency of PMP testing (see table below). PMP frequency can only be reduced once. However, if subsequent PMP test results fail to demonstrate compliance with the permit limits, then the frequency of PMP testing shall revert to the Initial Frequency.

<b>Initial Frequency, from Presumptive Norm</b>	<b>Minimum Duration between PMP Tests</b>	<b>Consecutive PMP Test Results Showing Compliance with Permit Limits</b>	<b>Reduced Frequency</b>
Semiannually	90 calendar days	6 consecutive semiannual test results	Annually
Quarterly	45 calendar days	8 consecutive quarterly test results	Annually
Monthly	15 calendar days	12 consecutive monthly test results	Quarterly

#### **Note**

The following text shall be added to the compliance plan under Monitoring Requirement: The initial Periodic Monitoring Procedure (PMP) frequency may be reduced from [semiannually](#) to [annually](#) after [6 consecutive semiannual test results](#) showing compliance with the permit limits. The minimum duration between PMP tests shall be [90](#) calendar days. The permittee must request a reduction in PMP frequency through the modification procedures.